

Oldham Borough Council
Record of Decision



Key Decision	Work Programme Reference
--------------	--------------------------

1. **TITLE:** Horton Mill Community Primary School - New Domestic Water Services and Leak Protection Equipment

2. **SERVICE AREA:**

3. **PURPOSE OF DECISION**

Horton Mill Community Primary School has been experiencing bursts on the hot and cold-water pipework for the last five years.

The domestic hot and cold-water pipework is failing on a regular basis. The copper pipework is corroding from the inside out, forming pinholes that result in leaks throughout the school. The pipework will continue to corrode and is beyond the point that any remedial action can be taken. As a result, the leaks will continue, potentially becoming worse.

A number of point of use water heaters are approaching the end of their useful life, resulting in an increased risk of failure and contamination into any newly replaced pipework.

4. **DECISION MADE BY:** Executive Director for Place & Economic Growth

5. **DECISION:**

Horton Mill Community Primary School has been experiencing bursts on the hot and cold-water pipework for the last five years.

The domestic hot and cold-water pipework is failing on a regular basis. The copper pipework is corroding from the inside out, forming pinholes that result in leaks throughout the school. The pipework will continue to corrode and is beyond the point that any remedial action can be taken. As a result, the leaks will continue, potentially becoming worse.

A number of point of use water heaters are approaching the end of their useful life, resulting in an increased risk of failure and contamination into any newly replaced pipework.

6. **REASON FOR DECISION**

No decision made.

7. **ALTERNATIVE OPTIONS CONSIDERED**

No decision made.

8. **INTERESTS AND NATURE OF INTERESTS DECLARED**

FIELD_DECISION_INTERESTS

9. **PRINCIPAL GROUPS CONSULTED:**

10. **DOCUMENT CONSIDERED:**



Oldham
Council